


Office of Civil Surgeon, Tarn Taran

No. CSTT /San/04

Date: 26/02/2024.

To Whom It May Concern

This is to certify that we have inspected Universal Academy
Bath Road, Tarn Taran After inspecting their toilets and
other rooms, we can certify that their cleanliness and sanitation is good.
Their water is Potable through RO System as per report of Rural Water
Supply and Sanitation Department. This certificate is valid for one year
from the date of issue. No. Heath Hazard is seen in the premises of the
school. There are separate washroom for girls and boys.


District Epidemiologist
TARN TARAN
District Epidemiologist
Tarn Taran


DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1@gmail.com

TEST REPORT

Name & Address of Customer : Universal Academy Savitri Square Bath Road , Tarn Taran		Customer Reference No.	No : 366 Dated : 04/09/2023			
		Sample Submitted by	Mr. Chanpreet Singh			
		Date of Sample Receipt	04/09/2023			
		Analysis Starting Date	04/09/2023			
		Analysis completion Date	05/09/2023			
Discipline : Chemical Testing		Group: Water				
ULR No.:	TC103872300000222F	Sample Type :	Treated Water			
Test Report No.:	DWTLTT/2324/00146	Date of Issue :	05/09/2023			
Registration no.:	DWTLTT/REG2324/00294	Condition of Sample :	Unsealed			
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Bath Road / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Not Mentioned	District :	Tarn Taran			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.20	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	30	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.01	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	20	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	16	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	4.81	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	0.97	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	7.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%



Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

----- End of the Test Report -----